

Loss Bulletin

Vero Engineering Insurance

Public utility transformer breakdown spoils food

Loss details

Nature of business

Banquet hall

Type of equipment

Utility owned 1500 KVA transformer

Age of equipment

10 years old

At 7pm on a warm Saturday evening in December the banquet hall was operating at capacity, catering for two weddings of over 350 guests. The electrical power to the hall was interrupted due to the burnout of the transformer supplying the insured's premises. The two receptions had to be cut short because power could not be restored until 5am Sunday morning.

The insured lost the income from the abbreviated receptions. They also lost most of the food in cold storage on the premises, which quickly spoiled in the hot, humid conditions.

Final loss

Settlement Amount \$20,500.00



How can I find out more?

To find out more about Vero Engineering Insurance contact your broker or visit the Vero website www.vero.com.au.