

# Loss Bulletin

## Vero Engineering Insurance

### UPS

#### Loss details

#### Nature of business

Technology services company

#### Type of equipment

A 60kVA UPS unit and an air conditioning unit

Following the interruption of power from the street mains, the Insured's back-up generator cut in to continue power supply to the premises. But power supply resumed on only 2 of the 3 phases. This caused damage to a UPS and a small air conditioner in the server room.

#### Final loss

The cost of a replacement UPS was \$60,450 and repair of the air conditioning unit amounted to \$760.



#### How can I find out more?

To find out more about Vero Engineering Insurance contact your broker or visit the Vero website [www.vero.com.au](http://www.vero.com.au).